



NNEX FOR VERIFICATION OF COMPLIANCE

CXMCP1104027

Summary of test result(s):

Test items	Test methods	Test results
Apparent density	EN 14617-1:2005	2380 kg/m ³
Water absorption	EN 14617-1:2005	0.04% Classification: W4
Flexural strength	EN 14617-2:2008	46.9MPa Classification: F4
Split resistance (polished)	EN 14231:2003	SRV "dry": 54 SRV "wet": 12
Abrasion resistance	EN 14617-4:2005	21.6mm Classification: A ₄
Impact resistance	EN 14617-9:2005	3.99J
Chemical resistance	EN 14617-10:2005	Classification: C ₄
Linear thermal expansion coefficient	EN 14617-11:2005	17.78 x 10 ⁻⁶ /°C
Dimensional stability	EN 14617-12:2005	Classification: A
Compressive strength	EN 14617-15:2005	232.0MPa
Moh's hardness	EN 101:1991	3.5
Dimensions, geometric characteristics and surface quality	EN 14617-16:2005	Tolerance: Pass Surface quality: No defect

For detail information, see test report No.: XMML110301328